

Date: 29<sup>th</sup> April 2017

CLARIFICATIONS TO PRE-BID QUERIES		
KOLKATA METRO RAIL CORPORATION LIMITED		
Contract-UG/EL-L & E (R) – Detailed Design, Detailed Engineering, Prototype, Manufacture, Supply, Delivery and Storage at Site, Installation, Testing And Commissioning (including integrated testing & commissioning), Training of Personnel, Demonstration of Performance of System/ Equipment & Annual Maintenance Contract of Lift & Escalator System (L & E) of Two Underground and Six Elevated Stations of Kolkata Metro East-West Line Project (Phase1)		
CONTRACT – UG/EL-L & E (R)		
	QUERIES	CLARIFICATIONS
1	Page No 16 of 302 (technical specifications) Clause A1.1-3 mentions Hairline Finish Stainless Steel (Grade 316) , however Volume 3 Part 1 Employer specifications 6.8.10 Car Interior & Elevator Finishes mention SS304 5WL Finish. Please clarify which finish is to be considered.	All the finishes for the elevator viz car interior finish, architrave finish etc should be considered as per technical specification Volume-3 Part 1, i.e. <b>SS 304 5WL</b> <b>Please refer to Clause 6.8.3, 6.8.10, 6.9.3, 6.11.2, 6.16.1, 6.29.1, 6.29.3 of Technical Specification Volume 3 part-1 and also sl no. 21 of Addendum no. 1 Dated 30<sup>th</sup> March 2017.</b>
2	We request you to share the soft copy (in MS Excel) of BOQ as we are finding it very difficult and time consuming to work on the same.	We do not have excel file for BOQ, However Word soft copy may be shared, if the Bidder requires so.
3	We request you to kindly extend the last date of submission of the said tender up to <b>31-May-2017</b> .	Please note that further extension of last date of submission of tender shall not be allowed and <b>the date for submission and opening of tender shall remain unchanged as 11<sup>th</sup> May 2017 as per Addendum No 2</b>